

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20202666
Address: 4708 NE SARATOGA CT, LEES SUMMIT, MO 64064

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Occupancy Inspection - Codes Residential	Khanh Nguyen	Failed	Wednesday, June 16, 2021

Corrective Action Required:

1	Misc	-Sidewalk not completed -Final grade, sod, downspout and sump pump extensions -Water meter is buried. Top lid of water meter pit must be at final grade -Make sure that the sewer tracer wire and port are installed and available at grade level -Clean out all dirt from inside the AC unit -Some downspouts are buried below soil -Screw the embedded brace into studs -Fb garage wall penetration below sink
---	------	---------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------

Comments: