

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRCOM20202637  
Address: 1001 SE BAILEY RD, LEES SUMMIT, MO 64081

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>Underslab Electrical Inspection</b> <b>- Commercial</b>	Robb Popp	Partial	Wednesday, June 16, 2021

Corrective Action Required:

1	THE FOLLOWING AREAS ARE APPROVED	-AREA "A" COMPLETE -AREA "B" COMPLETE -AREA "C" COMPLETE  -AREA "F" GYM COMPLETE SATAGE/PERFORMANCE COMPLETE  -AREA G- (2) UFERS FOR SERVICE PANELS NORTH AND SOUTH ROOM G110 -CONDUIT FROM G110 FOR POWER TO BLDS A,B,C -CONDUIT FOR MAIN SERVICE FROM CT CABINETS NORTH AND SOUTH TO G110 -G110, G111 COMPLETE
---	--	---

Comments: