

DEVELOPMENT SERVICES

Residential Plan Review

June 17, 2021

H & R CONSTRUCTION LLC 1200 S POWELL RD STE A INDEPENDNECE, MO 64057 (816) 229-4853

Permit No: PRRES20212953

Plan Name:

Project Address: 517 SE CARTER RD, LEES SUMMIT, MO 64082

Parcel Number: 70500060600000000

Location: COBEY CREEK 1ST PLAT --- LOT 18

Type of Work: NEW SINGLE FAMILY

Occupancy Group: RESIDENTIAL, ONE- AND TWO-FAMILY

Description: NEW HOUSE - FINISHED BASEMENT - COVERED DECK

Revisions Required

The following is a list of requirements from the City of Lee's Summit that have not been satisfactorily addressed in the plans and specifications. Please address the comments as requested and provide two (2) copies of any revised sheets and/or additional information.

Development Services Department (816) 969-1200

Plot Plan Review Reviewed By: Kim Brennan Approved

1. The Basement floor elevation and basement type (e.g. full/standard, daylight, walk-out, etc.)

Please indicate whether this is a standard or daylight basement

2. Minimum Building Opening Elevation (MBOE) and location on structure must be provided on the plot plan.

All the MBOE's were eliminated on this lot on the MDP

3. Contours, spot elevations and drainage flow arrows (as required) shall be provided on the lot.

Please add contours thoughout the lot and label these elevations and not just in selected areas. The drainage in the rear shows it going from one side of the lot to the other side in the rear. Is this an accurate flow?

The review conducted by the City of Lee's Summit Development Services Department shall not be construed as a structural review of the project.

Residential Area:

Residential, Finished basements		1045					
Residential, Living Area Residential, Un-Finished basements Residential, Decks Residential, garage		1812 775 180 705					
				Roofing Material		Number of Bathrooms	3
				Number of Bedrooms	5	Number of Stories	1
Number of Living Units	1	Total Living Area	2857				
Sewer Connection Fee	13						