

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRCOM20210599  
Address: 2051 NW LOWENSTEIN DR, LEES SUMMIT, MO 64081

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>Pavement-Proof Roll</b>	Joe Starlin	Passed	Thursday, June 17, 2021

Informational:

1 Misc

6-17-21 9:45am 81 degrees and full sun. The parking lot has passed the proof roll with three small corrections to be made. They will make the corrections with flowable fill. Two of the corrections are in the drive through lane and the third is between the storm inlets on the NW side of the site. They will be laying asphalt tomorrow 6-18-21.

**Comments:**