

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20210695
Address: 206 NW JOSHUA DR, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
All Rough Inspection - Residential	Michael Harkins	Failed	Thursday, June 17, 2021

Corrective Action Required:

1	Miscellaneous Correction	: PFH PORTAL FRAME, TRUSSES PORCH & COVERED PATIO ONLY :
		PFH Portal frame fasten top plate to header with 2 rows of 16D sinkers 3" OC per plan Spliced edges shall occur over and be nailed to common blocking within middle 24" of wall mid height one row of 3" OC Porch ok to cover lid Patio ok to cover lid

Comments: