



PLAN REVIEW CONDITIONS

June 17, 2021

Core States
6500 Chippewa St, Suite 200
St Louis, MO 63109

Permit No: PRCOM20212244
Project Title: CHASE BANK
Project Address: 890 NE LANGSFORD RD, LEES SUMMIT, MO 64063
Parcel Number: 61210113702000000
Location: STAR FUEL CENTER OF LEES SUMMIT---LOT 1 (EX PT TAKEN FOR ROW)
Type of Work: NEW COMMERCIAL
Occupancy Group: BUSINESS
Description: NEW BANK WITH DRIVE-THRU ATM UNDER DETACHED CANOPY

The following is a list of requirements from the City of Lee's Summit that have not been satisfactorily addressed in the plans and specifications. Please contact the appropriate department regarding clarification of comments.

Development Services Department (816) 969-1200

Fire Department (816) 969-1300

Fire Plan Review

Reviewed By: Michael Weissenbach

Approved

Building Plan Review

Reviewed By: Joe Frogge

Pending

1. The building permit for this project cannot be issued until the Development Services Department has received, approved, and processed the Final Development Plan.

Action required: Comment is for informational purposes.

2. A License Tax application completed by the contractor must be submitted to the City of Lee's Summit, Codes Administration Department, and any applicable License Tax paid prior to issuing a building permit.

Action required: Comment is for informational purposes.

3. Code of Ordinances Section 8.330. CPTED Review Requirement.

All development applications shall be subject to CPTED review and recommendations. The application of CPTED concepts and strategies is site specific and the level of review shall be determined on a case by case basis. Some requests during development review will require mandatory compliance. Others will be strongly encouraged but compliance will be voluntary. Mandatory compliance elements will be addressed in Article 9 "Uses with Conditions".

Section 8.340. CPTED Uses Specified The following uses have been classified as "Uses with Conditions" per

Article 9 of this Chapter, having been determined with a tendency toward an increased risk of crime,. Specific conditions for such uses are found in Article 9 and shall be required to be met prior to receiving any zoning approval, business license or approval to occupy any commercial space.

1. Bank/Financial Services
2. Bank Drive-Thru Facility
3. Check Cashing and Payday Loan Business
4. Convenience Store (C-Store)
5. Financial Services with Drive-up Window or Drive-Thru Facility
6. Pawn Shop
7. Title Loan Business, if performing on site cash transactions with \$500 or more in cash on hand
8. Unattended self-serve gas pumps
9. Unsecured Loan Business
10. Other similar uses shall meet the same standards as the above

Action required: Submit drawings or detailed report/spec to demonstrate compliance. A separate review for CPTED requirements must be performed. Permit will not be issued until CPTED review is approved.

4. 2018 IBC 1803.1 General. Geotechnical investigations shall be conducted in accordance with Section 1803.2 and reported in accordance with Section 1803.6. Where required by the building official or where geotechnical investigations involve in-situ testing, laboratory testing or engineering calculations, such investigations shall be conducted by a registered design professional.

Action required: Provide soils report to justify design assumption of soil bearing capacity greater than 2,000psf.

5. 2017 NEC Article 210.8 (B) Other Than Dwelling Units. All 125-volt, single-phase, 15- and 20-ampere receptacles installed in the locations specified in 210.8(B)(1) through (10) shall have ground-fault circuit-interrupter protection for personnel.

- (1) Bathrooms
- (2) Kitchens
- (3) Rooftops
- (4) Outdoors
- (5) Sinks - where receptacles are installed within 6 feet of the outside edge of the sink.
- (6) Indoor wet locations
- (7) Locker rooms with associated showering facilities
- (8) Garages, service bays, and similar areas other than vehicle exhibition halls and showrooms.
- (9) Crawl spaces – at or below grade level.
- (10) Unfinished portions or areas of the basement not intended as habitable rooms.
(refer to code for exceptions)

Action required: Modify drawings to show that all receptacles within 6' of a sink will be GFCI protected.
(ref: Janitor Closet 114)

6. Unable to find reference to NG piping spec.

Action required: Specify NG pipe materials.

The approval of plans and specifications does not permit the violation of any section of the Building Codes or other City Ordinances or State Law.

The review conducted by the City of Lee's Summit Development Services Department shall not be construed as a structural review of the project.