

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20203754
Address: 1504 SW SUGAR TREE DR, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Occupancy Inspection - Codes Residential	Mark Harding	Failed	Thursday, June 17, 2021

Corrective Action Required:

1	Misc	- final grade, check - as-graded plot plan -water meter leaking , pit full of water. lid needs to be flush with grade. -splash blocks, sump drain, gutters etc., sod. - deck: posts spliced not continuous deck posts. - sheetrock box out in garage. -label dedicated outlets, garage and basement. - install lag bolts at 16"o.c. - insude hangers installed at rim joist is not the correct hanger. install approved hanger.
---	------	---

Comments: