

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20211596
Address: 1862 NE PARK RIDGE DR, LEES SUMMIT, MO 64064

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Final Building Inspection - Residential	Khanh Nguyen	Failed	Thursday, June 17, 2021

Corrective Action Required:

1	Misc	-EXPOSED NM CABLE INSIDE THE BATHROOM CABINET MUST BE PROTECTED -PROVIDE ONE AVAILABLE GFCI-PROTECTED RECEPTACLE IN THE SUMP PUMP RM
---	------	---

Comments: