

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20203786
Address: 153 NW CARSON DR, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Driveway Inspection	Nick Lightner	Passed	Friday, June 18, 2021

Informational:

1	Misc	6/14/21 9:00AM- Drive approach has been compacted and is 6in deep, informed the crew to carry 1.5% for the sidewalk, to use KCMMB mix and to place expansion joint on the curb line.
---	------	--

Informational:

2	Misc	6/18/21 8:20- Driveway is carrying the correct % of slope for the sidewalk, expansion joints placed on the curb and easement line, and correct cure was placed.
---	------	---

Comments: