

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20203786
Address: 153 NW CARSON DR, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Sidewalk Inspection	Nick Lightner	Passed	Friday, June 18, 2021

Informational:
1 Misc 6/14/21 9:00AM- Sidewalk is 4in in depth, 5ft off the back of the curb, 5ft wide and is carrying 1.5% or less. Sidewalk and drive are good to pour.

Informational:
2 Misc 6/18/21 8:20- Sidewalk is carrying the correct % throughout it and has the correct cure placed.

Comments: