

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRRES20204591  
Address: 107 NW GRADY CT, LEES SUMMIT, MO 64081

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>Sidewalk Inspection</b>	Nick Lightner	Passed	Friday, June 18, 2021

Informational:  
1 Misc 6/14/21 15:30- Crew had 4in depth sidewalk, tamped down gravel, 5ft off the curb, and carried 2% or less.

Informational:  
2 Misc 6/18/21 8:55- Sidewalk was poured, carried correct % and was cured correct.

**Comments:**