

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20204543
Address: 103 NW GRADY CT, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Sidewalk Inspection	Nick Lightner	Passed	Friday, June 18, 2021

Informational:
1 Misc 6/14/21 15:25- Crew has rock tampered down, sidewalk is 4in depth, 5 ft from the back of the curb and carried 2% or less.

Informational:
2 Misc 6/18/21 9:00- Sidewalk is carrying the correct %, has the correct cure, and meets ada specs.

Comments: