

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20204544
Address: 210 NW JOSHUA DR, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Driveway Inspection	Nick Lightner	Passed	Friday, June 18, 2021

Corrective Action Required:

1	Misc	Forms were placed and aggregate was present and compacted. Forms need to be adjusted to meet ADA compliance. RP 5-25-21
---	------	-------------------------------------------------------------------------------------------------------------------------

Corrective Action Required:

2	Misc	Forms have not been adjusted yet. Please call in for another inspection. RP 6-4-21
---	------	------------------------------------------------------------------------------------

Informational:

3	Misc	6/14/21 15:45- 6in depth, rock has been tamped down, forms showed 2% or less I told them to keep the correct slop for the sidewalk.
---	------	-------------------------------------------------------------------------------------------------------------------------------------

Informational:

4	Misc	6/18/21 9:05- Drive has been poured, carrying the correct % for the sidewalk, and correct cure was placed.
---	------	------------------------------------------------------------------------------------------------------------

Comments: