

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRCOM20211884  
Address: 350 SW LONGVIEW BLVD, LEES SUMMIT, MO 64081

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>Rated Assembly Inspection</b>	John Morris	Partial	Friday, June 18, 2021

Informational:

1 Misc

Partial approval of rated assembly between occupancies.

-Screw pattern approved both sides of assembly

-complete fireblocking at roof deck and at all through/membrane penetrations of assembly

**Comments:**