

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRRES20210283  
Address: 317 NW AMBERSHAM DR, LEES SUMMIT, MO 64081

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>All Rough Inspection - Residential</b>	Michael Harkins	Partial	Monday, June 21, 2021

Partial Correction:

1 Misc

GARAGE PORTAL FRAMING OK TO COVER  
COVERED DECK TRUSSES OK TO COVER  
FRONT PORCH TRUSSES OK TO COVER  
: ONLY THE ABOVE ITEMS INSPECTED :

SHEATHING REQUIRES NAILING PER CODE BEFORE INSTALLING HARDIE BOARD SIDING

**Comments:**