

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRRES20210157  
Address: 2033 NW ASHURST DR, LEES SUMMIT, MO 64081

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>All Rough Inspection - Residential</b>	Patrick Schonfeldt	Failed	Monday, June 21, 2021

Corrective Action Required:

1	Misc	Provide solid blocking at sheathing breaks above garage door Provide pressure for gas test - gauge at 8 psi, must maintain 10 psi Nail sheathing per code Provide 3 studs & bottom plate w/ anchor bolts east & west corners basement - bottom plate and stud added, anchor bolt req at bottom plate  **OK TO INSULATE**
---	------	--

Comments: