

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20210438
Address: 2048 NW ASHURST DR, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
All Rough Inspection - Residential	John Morris	Failed	Tuesday, June 22, 2021

Corrective Action Required:

1	Misc	-Two rows of 16D sinker nails 3" oc at braced wall panel top plates per plan, see section view of detail -continue 3" OC fastening exterior sheathing to top plate -no truss hold downs visible front covered porch -no covered rear deck
---	------	--

Comments: