

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRRES20210467  
Address: 2049 NW ASHURST DR, LEES SUMMIT, MO 64081

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>All Rough Inspection - Residential</b>	John Morris	Failed	Tuesday, June 22, 2021

Corrective Action Required:

1	Misc	-Two rows of 16D sinker nails 3" oc at braced wall panel top plates per plan, see section view of detail -Unable to verify 3" OC exterior sheathing fastening at top plate -Install Truss hold down devices, rear deck -covered front porch approved
---	------	---

**Comments:**