

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRCOM20211884
Address: 350 SW LONGVIEW BLVD, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Rated Assembly Inspection	John Morris	Passed	Tuesday, June 22, 2021

Informational:

1 Misc

Partial approval of rated assembly between occupancies.

-Screw pattern approved both sides of assembly

-complete fireblocking at roof deck and at all through/membrane penetrations of assembly

Comments: