

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20210744
Address: 2155 NW KILLARNEY LN, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
All Rough Inspection - Residential	Michael Harkins	Partial	Tuesday, June 22, 2021

Corrective Action Required:

1	Misc	: GARAGE PORTAL FRAME ONLY : 3" O.C. NAILING PATTERN & HOLD DOWN NAILING APPROVED OK TO COVER CHECK BELOW ON ROUGH IN PROVIDE HEADER TO JACK STUD TENSION STRAPS ADDRESS OVER NOTCHED STUDS @ 5/8 ANCHOR BOLTS
---	------	--

Comments: