



PLANS REVIEW CONDITIONS

Permit No:	PRCOM20211431	Date:	June 22, 2021
Project Title:	CLUB PILATES	Applicant:	
Location:			
940 NW PRYOR RD, Unit:E, LEES SUMMIT, MO 64081	AEGIS FIRE PROTECTION LLC		
Type of Work:		11936 W 119TH ST #262	
Occupancy Group:	A-4	OVERLAND PARK, KS 66213	
Description:	TENANT FINISH FOR PILATES GYM		
Construction Type:	Type IIB (Unprotected)	Primary:	(913) 825-0343
Map Page:			

Listed below are requirements from our department for the project noted above. If you have any additional questions, please contact our department for further clarification.

Alarm Plan Review

Reviewed By: Michael Weissenbach

Released for Construction

1. 2018 IFC 901.5- Installation acceptance testing. Fire detection and alarm systems, fire-extinguishing systems, fire hydrant systems, fire standpipe systems, fire pump systems, private fire service mains and all other fire protection systems and appurtenances thereto shall be subject to acceptance tests as contained in the installation standards and as approved by the fire code official. The fire code official shall be notified before any required acceptance testing. The fire code official shall be notified 48 hours before any required acceptance test.
(Informational Purposes)
Call (816)969-1300 to schedule testing.

The applicant understands that the requirements listed above must be corrected to conform to applicable City Codes and Ordinances.