

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20210696
Address: 2053 NW ASHURST DR, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
All Rough Inspection - Residential	Michael Harkins	Partial	Tuesday, June 22, 2021

Corrective Action Required:

1	Misc	GARAGE PORTAL FRAME 3" O.C. NAILING & HOLD DOWNS NAILED OFF OK TO COVER TRUSSES FRONT PORCH TRUSS LOCK SCREWS IN PLACE OK TO COVER CHECK BELOW ON ROUGH IN PROVIDE 4 STUD PACK AT GIRDER TRUSS BEARING POINTS PER ROOF PLAN G-1 TRUSS AT FRONT PORCH
---	------	--

Comments: