

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20212771
Address: 4408 SW LODESTONE DR, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
All Rough Inspection - Residential	Patrick Schonfeldt	Failed	Tuesday, June 22, 2021

Corrective Action Required:

1	Misc	-NAIL PROTECTION PLATES AT ALL DWV LESS THAN 1 1/4" FROM END OF STUD -FIREBLOCK ABOVE SERVICE PANEL BETWEEN TOP PLATE AND FOUNDATION WALL -SECURE VERTICAL NM TO STUD AT BATHROOM -COMPLETE ALL FURRED DOWNS ON CEILINGS IF APPLICABLE
---	------	---

Comments: