

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20211894
Address: 2111 NW KILLARNEY LN, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Piers/Caissons Inspection - Residential	Michael Harkins	Passed	Tuesday, June 22, 2021

Informational:
1 Misc 3RD PARTY BY BOB ROWE @ VAN DEURZEN SIGNED & SEALED BY CHAD STREETER
DRILLED PIER FOUNDATION
(39) 18" X 10'-14' BEARING ON BLUE SHALE AND LIMESTONE

Comments: