

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20204780
Address: 2025 NW ASHURST DR, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
All Rough Inspection - Residential	Michael Harkins	Not Ready	Tuesday, June 22, 2021

Corrective Action Required:

1	Misc	Note only for ALL-Rough R302- 2018 IRC At garage wall needs to be rated as per section 302 both sides. (NAIL PYRO-GUARD PER CODE 6" & 12") Provide CS-PF straps per plan basement SGD Provide 1 1/2 bearing deck beam Solid block top plate to roof deck complete west wall (SEAL BLOCKING) SEAL UPWARD PENETRATIONS AT PANTRY, SGD BASEMENT, DEAD SPACE FRONT BEDROOM
---	------	--

Comments: