

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20202029
Address: 1245 NE GOSHEN DR, LEES SUMMIT, MO 64064

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
All Rough Inspection - Residential	Khanh Nguyen	Failed	Wednesday, June 23, 2021

Corrective Action Required:

1	Misc	-Seal penetrations of ceiling joist return air space. **Seal basement bedroom return air gap penetrations
		-Fb stair stringer space from fur down ceiling space **not done right. Take off the paper facing and pack in tightly do there is no gap
		-Half bathroom fan duct outside joist space **frame around the bath fan duct above garage. Nothing done
		-Install fireplace **Need installation manual
		**6/23-RE-INSPECTION FEE ASSESSED

Comments: