CITY OF LEE'S SUMMIT Development Services Department 220 SE Green Street Lee's Summit, MO 64063 (816)969-1200

DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20204249

Address: 118 NW GRADY CT, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection: Inspector: Outcome: Date:

Occupancy Inspection - Codes Patrick Schonfeldt Failed Wednesday, June 23,

Residential 2021

Corrective Action Required:

1 Misc -Resolve outstanding inspection fees before final c of o

-Final grade and sod

-splash blocks at all sump pump and downspout discharge locations, min 36"

discharge from foundation

-Install light fixture at basement bath vanity, exposed NM at wall

-Full height continuous 6x6 cedar posts at deck per plans

-(2) 1/2" through bolts required at each post/beam connection at deck

R507.5.1(2)

-Inspection will be required of garage used as sales office after conversion

back to garage for sale

Comments: