

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20210592
Address: 134 NW AMBERSHAM DR, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
All Rough Inspection - Residential	Michael Harkins	Failed	Wednesday, June 23, 2021

Corrective Action Required:

1	Misc	: PORTAL FRAME ONLY : NAIL OFF HOLD DOWNS FASTEN TOP PLATE TO HEADER WITH TWO ROWS 16D SINFERS 3" O.C. FASTEN SHEATHING TO HEADER, STUDS BLOCKING IN 3" GRID PATTERN
---	------	--

Comments: