

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20210157
Address: 2033 NW ASHURST DR, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
All Rough Inspection - Residential	Michael Harkins	Not Ready	Thursday, June 24, 2021

Corrective Action Required:

1	Misc	Provide solid blocking at sheathing breaks above garage door (2 car overhead door) Provide pressure for gas test - gauge at 8 psi, must maintain 10 psi (only 5 psi)
---	------	--

****OK TO INSULATE****

Comments: