

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20204525
Address: 111 NW GRADY CT, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

| Inspection: | Inspector: | Outcome: | Date: |
|---|------------|----------|-------------------------|
| All Rough Inspection - Residential | Robb Popp | Failed | Thursday, June 24, 2021 |

Corrective Action Required:

| | | |
|---|------|--|
| 1 | Misc | **Basement finish: -Provide bocca plate for dwv at bottom plate in bath |
|---|------|--|

Comments: