

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRCOM20203513
Address: 400 SE BLUE PKWY, LEES SUMMIT, MO 64063

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Rated Assembly Inspection	Michael Harkins	Partial	Thursday, June 24, 2021

Informational:
1 Misc : THE FOLOWING AREAS ARE APPROVED :
PRESS BOX ELEVATOR SHAFT 1" GYPSUM BOARD INNER SHAFT ALL FLOORS
- 1ST LAYER 5/8 TYPE X OUTSIDE ELEVATOR SHAFT ALL FLOORS -

Comments: