

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20204954
Address: 345 NW AMBERSHAM DR, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
All Rough Inspection - Residential	Michael Harkins	Not Ready	Friday, June 25, 2021

Corrective Action Required:

1	Misc	Seal fire blocking chases in great room Seal DWV top plate penetrations outside gym/bath # 4 & rec room Fire block (insulate) beam pockets Fire block (insulate) soffit above service panel Provide 4 stud pack at GT bearing points per roof plan (MASTER CLOSET) Seal dead space master bed door
---	------	--

Comments: