

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20204325
Address: 4391 SW AMETHYST DR, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Occupancy Inspection - Codes Residential	Patrick Schonfeldt	Failed	Monday, June 28, 2021

Corrective Action Required:

1	Misc	-Final grade and sod -splash blocks at downspout and sump pump discharge, min 36" discharge from foundation -Install oven, no receptacle seen in cabinet -Interconnection required of all smoke detectors- see 2nd floor bedroom S side -cover plates required master bath vanity receptacles -security screws at basement walkout -clip off set screw head on anti siphon, see basement spigot at main water line
---	------	--

Comments: