

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRRES20212664  
Address: 4050 SE DOC HENRY RD, LEES SUMMIT, MO 64082

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>All Rough Inspection - Residential</b>	Robb Popp	Failed	Tuesday, June 29, 2021

Corrective Action Required:

1	Miscellaneous Correction	-Provide (2) 1/2" through bolts at each post to beam connection -Support West post with (2) blocks in between joists -Provide ledger loks at end rafter to house connection
---	--------------------------	---

**Comments:**