

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20212098
Address: 1709 SW 27TH ST, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
-------------	------------	----------	-------

Pool Steel/Bonding - Residential	John Morris	Pending	
---	-------------	---------	--

Informational:

1	Misc	-conductor to equipment pad approved -light niche bonding approved -water bond approved (light niche) -metallic pool structure bonding approved
---	------	--

Corrective Action Required:

2	Misc	-Provide perimeter surface bonding Perimeter surface bonding not approved. See 2017 NEC 608.26(B)(2)(b) for alternate means when using non-metallic reinforcement. Bonding conductor to be placed 18-24" from inside wall of pool
---	------	--

Comments: