

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRRES20212098  
Address: 1709 SW 27TH ST, LEES SUMMIT, MO 64082

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>Pool Steel/Bonding - Residential</b>	John Morris	Passed	Tuesday, June 29, 2021

Informational:

1	Misc	-conductor to equipment pad approved -light niche bonding approved -water bond approved (light niche) -metallic pool structure bonding approved -perimeter surface bonding approved
---	------	---

Corrective Action Required:

2	Misc	Perimeter surface bonding not approved. See 2017 NEC 608.26(B)(2)(b) for alternate means when using non-metallic reinforcement. Bonding conductor to be placed 18-24" from inside wall of pool
---	------	--

Comments: