

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20202666
Address: 4708 NE SARATOGA CT, LEES SUMMIT, MO 64064

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Sidewalk Inspection	John Jackson	Passed	Tuesday, June 29, 2021

Informational:

1 Misc

Sidewalk - Forms and materials passed pre-inspection.

Partial Correction:

2 Misc

Needs white cure for sidewalk. Reminded contractor to install isolation joints between sidewalk and approach.

Comments: