

PLANS REVIEW CONDITIONS

Permit No: PRCOM20200773	Date: June 30, 2021
Project Title: LSMC Hybrid OR Addition	Applicant:
Location: 2100 SE BLUE PKWY, LEES SUMMIT, MO 64063	SIEMENS INDUSTRY INC P O BOX 80600 INDIANAPOLIS, IN 46280
Type of Work:	
Occupancy Group: I-2	
Description: LSMC Hybrid O.R. Addition	
Construction Type: Type IB	Primary: (317) 596-3260 Ext: 2546
Map Page:	

Listed below are requirements from our department for the project noted above. If you have any additional questions, please contact our department for further clarification.

Alarm Plan Review

Reviewed By: Michael Weissenbach

Released for Construction

1. 2018 IFC 901.5- Installation acceptance testing. Fire detection and alarm systems, fire-extinguishing systems, fire hydrant systems, fire standpipe systems, fire pump systems, private fire service mains and all other fire protection systems and appurtenances thereto shall be subject to acceptance tests as contained in the installation standards and as approved by the fire code official. The fire code official shall be notified before any required acceptance testing. The fire code official shall be notified 48 hours before any required acceptance test.
(Informational Purposes)
Call (816)969-1300 to schedule testing.

The applicant understands that the requirements listed above must be corrected to conform to applicable City Codes and Ordinances.