## CITY OF LEE'S SUMMIT Development Services Department 220 SE Green Street Lee's Summit, MO 64063 (816)969-1200 **DEVSERVICES.CITYOFLS.NET**

## **Inspection Summary**

Permit #: PRRES20210283 Address: 317 NW AMBERSHAM DR, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:		Inspector:	Outcome:	Date:
All Rough Inspection - Residential		Michael Harkins	Not Ready	Wednesday, June 30, 2021
Partial Co	rrection:			
1	Misc	COVERED DECK TRUSS FRONT PORCH TRUSSE : ONLY THE ABOVE ITEL SHEATHING REQUIRES SIDING THIS HAS IS COVERED V AREAS ARE NOT NAILE MASTER BEDROOM BC DEAD SPACE, GREAT RE	GARAGE PORTAL FRAMING OK TO COVER COVERED DECK TRUSSES OK TO COVER FRONT PORCH TRUSSES OK TO COVER : ONLY THE ABOVE ITEMS INSPECTED : SHEATHING REQUIRES NAILING PER CODE BEFORE INSTALLING HARDIE BOARD SIDING THIS HAS IS COVERED WITH TYVEK UNABLE TO VERIFY NAIL PATTERN BELOW AREAS ARE NOT NAILED PER CODE MASTER BEDROOM BOTH SIDES OF WINDOWS,BED # 2 / DINING ROOM AT DEAD SPACE, GREAT ROOMSE CORNER,FRONT DOOR, OFFICE CLOSET, BASEMENT REAR WALL, SOUTH WALL	

## Comments: