

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20204685
Address: 2911 SW ARBOR TREE DR, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Final Building Inspection - Residential	John Morris	Failed	Wednesday, June 30, 2021

Corrective Action Required:

1	Misc	-Provide combustion, dilution & ventilation openings from mechanical closet into living space -Smoke/carbon monoxide alarm required outside of sleeping area
---	------	---

Comments: