

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816) 969-1200 FAX (816) 969-1201

STOP WORK ORDER

**ANY UNAUTHORIZED PERSON REMOVING THIS NOTICE WILL BE
PROSECUTED**

Permit #: PRCOM20211976
Address: 811 NE LAKEWOOD BLVD, LEES SUMMIT, MO 64064

Any person who shall continue work after having been served with a stop work order, except such work as that person is directed to perform to remove a violation or unsafe condition, shall be subject to penalties as prescribed by law.

Inspection:	Inspector:	Outcome:	Date:
Miscellaneous Inspection	Mark Harding	Failed - Stop Work	Thursday, July 01, 2021

Corrective Action Required
1 Misc

Inspections were scheduled on the hand sink PRRES20213153 and electrical permit for 6/30.
upon the inspection we found a wall addition that contains the new electrical panel , plumbing, lighting, soda dispenser , this addition has no frost footing.
The plumbing for the sink exists exterior of the wall and runs on top of the ground. The proper coverage of a waste line for plumbing must be provided.
the Waste vent is on the exterior of the building.
See email sent to HD and Chris Smith.
no further inspections until the electrical from the previous permit has been approved.

Comments:

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816) 969-1200 FAX (816) 969-1201