

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRRES20212324  
Address: 2934 SW ARBORIDGE DR, LEES SUMMIT, MO 64082

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

| Inspection:                                                  | Inspector:         | Outcome: | Date:                   |
|--------------------------------------------------------------|--------------------|----------|-------------------------|
| <b>Underslab Plumbing Inspection</b><br><b>- Residential</b> | Patrick Schonfeldt | Failed   | Thursday, July 01, 2021 |

Corrective Action Required:

|   |      |                               |
|---|------|-------------------------------|
| 1 | Misc | -POST ADDRESS                 |
|   |      | -INTERIOR DRAIN TILE REQUIRED |

**Comments:**