



June 30, 2021

Summit Homes
120 SE 30th St.
Lee's Summit, MO 64082

RE: Field Issue deck beam attachment for Lot #6 Woodside Ridge – 110 NW Grady Ct. Lee's Summit, MO 64081 – Permit # PRRES20204536

This letter addresses the deck beam attachment for Lot # 6 Woodside Ridge.

The revision shall be as follows:

- Install (2) 1/4" x 6" lag screws per deck beam to post connection.
- Install screw head at inner edge of post to extend outward into deck beam and trim piece.
- Deck post is notched 2 ply for 2 ply deck beam.

Sincerely,

A handwritten signature in blue ink, appearing to read "B. Huxol", is written over a faint, larger blue signature.

Bradley Huxol, PE

