

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRSUBD20211138
Address: 1201 SW LONGVIEW BLVD, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Sanitary - Material Verification	Ronald Paynter	Passed	Friday, July 02, 2021

Informational:
1 Misc Manholes were manufactured by Barbour Concrete. They used ML-13-NR steps. SDR 26 sanitary pipe was manufactured by National. Manhole castings are EJ 1502 with the correct stamps on top. RP 7-2-21

Comments: