CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20201772
Address: 3202 SW PERGOLA PARK DR, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Driveway Inspection	Ronald Paynter	Passed	Friday, July 02, 2021

Informational:

1	Misc	Forms were placed and aggregate was present and compacted. Approach was set at 37 feet. Had them move the wings in until we were at 36 feet. RP 6-9-21

Informational:

2	Misc	Finished driveway is 35 1/2 feet wide and meets LS and ADA specs. RP 7-2-21

Comments: