

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRCOM20211431
Address: 940 NW PRYOR RD, Unit:E, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

| Inspection: | Inspector: | Outcome: | Date: |
|---------------------------------|-----------------|----------|-----------------------|
| Above Ceiling Inspection | Michael Harkins | Passed | Friday, July 02, 2021 |

Corrective Action Required:
1 THE FOLLOWING AREAS ARE APPROVED - HARD LID RESTROOM OK TO ROCK -

Comments: