

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20210076
Address: 2046 NW OBRIEN RD, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
All Rough Inspection - Residential	Michael Harkins	Failed	Tuesday, July 06, 2021

Corrective Action Required:

1	Miscellaneous Correction	No deck Pier inspection on record Install fireplace Land conductors in a box bed # 3, Bed #4 & bed # 5 Seal top plate penetration loft Nail joist hanger bed # 4 closet Tighten anchor bolts basement Provide BP1 blocking behind stair landing basement Nail siding east side per code
---	--------------------------	--------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------

Comments: