

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRRES20202666  
Address: 4708 NE SARATOGA CT, LEES SUMMIT, MO 64064

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>Sidewalk Inspection</b>	John Jackson	Passed	Tuesday, July 06, 2021

Informational:

1 Misc

Sidewalk - Forms and materials passed pre-inspection.

Informational:

2 Misc

Needs white cure for sidewalk. Reminded contractor to install isolation joints between sidewalk and approach.

Informational:

3 Misc

Sidewalk - passed final inspection.

**Comments:**