

DEVELOPMENT SERVICES

Residential Plan Review

July 06, 2021

JFE CONSTRUCTION INC 1314 SW MARKET ST LEES SUMMIT, MO 64081 (816) 470-0074

Permit No: PRRES20213385

Plan Name:

Project Address: 121 NW AMBERSHAM DR, LEES SUMMIT, MO 64081

Parcel Number: 62240252000000000

Location: WOODSIDE RIDGE 1ST PLAT LOTS 1 THRU 143 INCLUSIVE AND TRACTS A,B,C,D,E,F,G, AND H --- LOT

112

Type of Work: NEW SINGLE FAMILY

Occupancy Group: RESIDENTIAL, ONE- AND TWO-FAMILY

Description: NEW HOUSE - FINISHED BASEMENT - COVERED DECK

Revisions Required

The following is a list of requirements from the City of Lee's Summit that have not been satisfactorily addressed in the plans and specifications. Please address the comments as requested and provide two (2) copies of any revised sheets and/or additional information.

Development Services Department (816) 969-1200

Residential Plan Review Reviewed By: Kim Brennan Approved

1. Provide combustion air calculations and specify transfer air grilles for fuel burning appliances located in confined space(s). (IRC Chapter 17 and Section G2407)

The review conducted by the City of Lee's Summit Development Services Department shall not be construed as a structural review of the project.

Residential Area:				
Residential, Living Area		2134		
Residential, Un-Finished basements		421		
Residential, Finished basements		1454		
Residential, Decks		232		
Residential, garage		734		
Roofing Material		Number of Bathrooms	3.5	
Number of Bedrooms	4	Number of Stories	1	

Number of Living Units	1	Total Living Area	3588
Sewer Connection Fee	18		