

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRCOM20210833
Address: 940 NW PRYOR RD, Unit:H, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
In-wall Inspection	Michael Harkins	Failed	Wednesday, July 07, 2021

Corrective Action Required:

1	Misc	REPAIR DRYWALL AT CORRIDOR SEAL FLOOR PENETRATIONS SUPPORT VERTICAL DWV 2" & SMALLER AT MIDPOINT
---	------	--

THE FOLLOWING AREAS HAVE BEEN APPROVED
- IN WALL DWV WOMENS RESTROOM -

Comments: